Certificate of Compliance

This is a certificate of compliance to certify that the bearer has successfully completed the requirements of the above scheme which include the testing of products, the initial assessment, and are subject to continuing annual assessments of their compliance and testing of samples of products taken from production (as applicable to the scheme) and has been registered within the scheme for the products detailed.

You have been awarded:

Intertek WH US + C Mark for Category B - Doors - Additional Edge-sealing System Required, Category A - Doors - No Additional Edge-sealing System Required

Standards: CAN / ULC S104 (2015) (R2020), UL 10(c) (2016), UL 10(b) (2008) (R2015), NFPA 252 (2017)

Certificate number: WHI18-28731426

Organization: ARFAD International Industry Company
Building No. 4177, Road 118, 3rd Industrial Area
Al Jubail 35729
Kingdom of Saudi Arabia

Product: Halspan UniversaL 20-30 Minute Fire Door
Spec ID: 30289
Fire Rating: 30 Min PP Category B Door, 20 Min Positive Pressure
Listing Information: See following page(s)

Certification body: Intertek Testing Services NA, Inc.
Initial registration: March 13, 2018
Date of expiry: December 31, 2026
Issue status: 10

Authorized By: _____
Jean-Philippe Kayl, Director of Certification

Intertek Testing Services NA, Inc.
545 E. Algonquin Road, Ste H., Arlington Heights, IL 60005 USA
Phone: 847-439-5667 Fax: 847-439-7320

www.intertek.com

The certificate and schedule are held in force by regular annual surveillance visits by Intertek Testing Services NA, Inc. and the reader or user should contact Intertek to validate its status. This certificate remains the property of Intertek Testing Services NA, Inc. and must be returned to them on demand. This Certificate is for the exclusive use of Intertek's Client and is provided pursuant to the Certification agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this certificate. Only the Client is authorized to permit copying or distribution of this certificate and then only in its entirety. Use of Intertek's Certification mark is restricted to the conditions laid out in the agreement. Any further use of the Intertek name for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. Initial Factory Assessments and Follow up Services are for the purpose of assuring appropriate usage of the Certification mark in accordance with the agreement, they are not for the purposes of production quality control and do not relieve the Client of their obligations in this respect.

LISTING INFORMATION

PRODUCT COVERED

Halspan 44mm UniversaL Particleboard Fire Door

MAXIMUM SIZES AND RATINGS

20 Minutes Category A or Category B Doors
Additional Category G edge seal required if supplied as Category B door

Type	Max. Width	Max. Height	Thickness
Single Swing	4'0"	8'0"	1-3/4"
Pairs	8'0"	8'0"	1-3/4"
Double Egree	Not Allowed	Not Allowed	Not Allowed

30 Minutes Category B Door
Additional Category G edge seal is required on door frame

Type	Max. Width	Max. Height	Thickness
Single Swing	4'0"	8'0"	1-3/4"
Pairs	Not Allowed	Not Allowed	Not Allowed
Double Egress	Not Allowed	Not Allowed	Not Allowed

These doors must be installed in listed Category C - Standard or Proprietary frames. A surface applied Category G intumescent edge seal system is required to be used on the door frame for Category B doors. Please consult the frame manufacturer's listed installation instructions for any restrictions and limitations pertaining to the frame.

The door noted above is eligible to bear the "S" (for Smoke & Draft Control assemblies) if a listed "Category H - Smoke & Draft Control Gasket" has been applied to the assembly. Please refer to Category H for individual gasket manufacturer's listings.