Certificate of Compliance

You have been awarded:

WH Service Mark 2014 for Category D - Door/frame Assemblies, Doors

Standards: BS 476 Part 22 (1987)

Certificate number: WHI18-28731438

This is a certificate of compliance to certify that the bearer has successfully completed the requirements of the above scheme which include the testing of products, the initial assessment, and are subject to continuing annual assessments of their compliance and testing of samples of products taken from production (as applicable to the scheme) and has been registered within the scheme for the products detailed.

Organization: ARFAD International Industry Company
Building No. 4177, Road 118, 3rd Industrial Area
Al Jubail 35729
Kingdom of Saudi Arabia

Product: Halspan 90 Prima Plus
Spec ID: 42924
Listing Information: See following page(s)

Certification body: Intertek Testing Services NA, Inc.
Initial registration: March 13, 2018
Date of expiry: December 31, 2026
Issue status: 10

Authorized By: _____
Jean-Philippe Kayl, Director of Certification

Intertek Testing Services NA, Inc.
545 E. Algonquin Road, Ste H., Arlington Heights, IL 60005 USA
Phone: 847-439-5667 Fax: 847-439-7320

www.intertek.com

The certificate and schedule are held in force by regular annual surveillance visits by Intertek Testing Services NA, Inc. and the reader or user should contact Intertek to validate its status. This certificate remains the property of Intertek Testing Services NA, Inc. and must be returned to them on demand. This Certificate is for the exclusive use of Intertek's Client and is provided pursuant to the Certification agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this certificate. Only the Client is authorized to permit copying or distribution of this certificate and then only in its entirety. Use of Intertek's Certification mark is restricted to the conditions laid out in the agreement. Any further use of the Intertek name for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. Initial Factory Assessments and Follow up Services are for the purpose of assuring appropriate usage of the Certification mark in accordance with the agreement, they are not for the purposes of production quality control and do not relieve the Client of their obligations in this respect.

LISTING INFORMATION

PRODUCT COVERED

Halspan 90 Prima Plus Particleboard Fire Door Assembly for use in fire rated applications per BS 476 Part 22 (1987) for insulation and integrity ratings as specified below.

Insulation: See the table and glazing restrictions below. Insulation rating is dependent on glazing configuration, (See Machining Information section of listing for complete approvals, restrictions, and limitations).

Type		Details
Fully Insulating	Timber Frames	Unglazed doorsets or doorsets glazed with 5mm thick Firelite (see maximum allowed area below).

Integrity: 90 Minutes

MAXIMUM SIZES AND RATINGS

Allowable Configuration(s)	Maximum Size	Frame Type	Glazing	Overpanel	Intumescent
LSASD LSADD	1297mm wide x 2400mm high (LSASD) 1000mm wide x 3103mm high (LSASD) 2544mm wide x 2400mm high (LSADD) 2000mm wide x 3053mm high (LSADD)	Wood	Yes (Max. 0.25 sq. m)	No	Yes. (Halspan Type SLS)

Please note: Consult Manufacturing and Machining sections of this listing for hardware intumescent requirements.

DEFINITION KEY

LSASD - Latched Single Acting Single Doorset

LSADD - Latched Single Acting Double Doorset

Please consult Intertek or Halspan with any questions that pertain to the door construction referenced within this listing.