Certificate of Compliance

This is a certificate of compliance to certify that the bearer has successfully completed the requirements of the above scheme which include the testing of products, the initial assessment, and are subject to continuing annual assessments of their compliance and testing of samples of products taken from production (as applicable to the scheme) and has been registered within the scheme for the products detailed.

You have been awarded:

Intertek WH US + C Mark for Category B - Doors - Additional Edge-sealing System Required

Standards: CAN / ULC S104 (2015) (R2020), UL 10(c) (2016), UL 10(b) (2008) (R2015), NFPA 252 (2017)

Certificate number: WHI25-28731461

Organization: ARFAD International Industry Company
Building No. 4177, Road 118, 3rd Industrial Area
Al Jubail 35729
Kingdom of Saudi Arabia

Product: Halspan Ltd - Halspan Universal 60 Min 45mm Single Swing Wooden Composite Door
Spec ID: 67817
Fire Rating: 60 Min PP Category B Door
Listing Information: See following page(s)

Certification body: Intertek Testing Services NA, Inc.
Initial registration: February 19, 2025
Date of expiry: December 31, 2026
Issue status: 2

Authorized By:
Jean-Philippe Kayl, Director of Certification

Intertek Testing Services NA, Inc.
545 E. Algonquin Road, Ste H., Arlington Heights, IL 60005 USA
Phone: 847-439-5667 Fax: 847-439-7320

www.intertek.com

The certificate and schedule are held in force by regular annual surveillance visits by Intertek Testing Services NA, Inc. and the reader or user should contact Intertek to validate its status. This certificate remains the property of Intertek Testing Services NA, Inc. and must be returned to them on demand. This Certificate is for the exclusive use of Intertek's Client and is provided pursuant to the Certification agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this certificate. Only the Client is authorized to permit copying or distribution of this certificate and then only in its entirety. Use of Intertek's Certification mark is restricted to the conditions laid out in the agreement. Any further use of the Intertek name for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. Initial Factory Assessments and Follow up Services are for the purpose of assuring appropriate usage of the Certification mark in accordance with the agreement, they are not for the purposes of production quality control and do not relieve the Client of their obligations in this respect.

LISTING INFORMATION

FIRE RESISTANT PRODUCTS & COMPONENTS

CATEGORY B DOORS – ADDITIONAL EDGE-SEALING SYSTEM REQUIRED

PRODUCT COVERED
Halspan Universal 60 Min 45mm Single Swing Wooden Composite Door

Model: Halspan Universal 60 45mm range

Door Size (single swing):

Maximum Width: 1100 mm
Maximum Height: 2400 mm
Minimum Thickness: 45 mm

PRODUCT DESCRIPTION
Hardware Limitations:

Cylindrical Lock with maximum backet 2-3/4 in (70mm) and maximum cylindrical bore hole size of 2-1/8 in (54mm).

Configuration **Size**
Single Swing - 1100mm wide x 2400mm high x 45mm thick

Standard Pairs - Not allowed.

Double Egress- Not allowed.

For use with Halspan Mineral Frame (Model Halspan Universal 60 Composite frame range; Spec ID 67819) , Halspan - Universal Timber Composite Frame Section (Spec ID 64681).
Note - Application and Size limitations of the individual frame listings must also be considered for the final assembly.

Halspan Mineral Frame (Model Halspan Universal 60 Composite frame range) was fastened to an aerated concrete or masonry wall by steel bar with nail. The maximum clearance between the wall and the frame is 10mm and the clearance is filled with mineral wool clad with quick-setting cement.

The product noted above has been tested and qualified 1-hour positive pressure fire rated applications per UL 10C, NFPA 252, and 1-hour neutral pressure fire rated applications per CAN/ULC-S104, UL 10B.