Certificate of Compliance

You have been awarded:

Intertek WH US + C Mark for Category D - Door/frame Assemblies

Standards: CAN / ULC S104 (2015) (R2020), UL 10(b) (2008) (R2015), UL 10(c) (2016) Ed. 3 (R:27 May 2021), NFPA 252 (2022)

Certificate number: WHI26-28731467

This is a certificate of compliance to certify that the bearer has successfully completed the requirements of the above scheme which include the testing of products, the initial assessment, and are subject to continuing annual assessments of their compliance and testing of samples of products taken from production (as applicable to the scheme) and has been registered within the scheme for the products detailed.

Organization: ARFAD International Industry Company
Building No. 4177, Road 118, 3rd Industrial Area
Al Jubail 35729
Kingdom of Saudi Arabia

Product: Halspan – Universal HD Core Wooden Door with Composite / Steel Frame Assembly – UL 10C
Spec ID: 84341
Fire Rating: 60 Min PP Category D Door/Frame Assemblies, 90 Min PP Category D Door/Frame Assemblies
Listing Information: See following page(s)

Certification body: Intertek Testing Services NA, Inc.
Initial registration: February 21, 2026
Date of expiry: December 31, 2026
Issue status: 1

Authorized By:
Jean-Philippe Kayl, Director of Certification

Intertek Testing Services NA, Inc.
545 E. Algonquin Road, Ste H., Arlington Heights, IL 60005 USA
Phone: 847-439-5667 Fax: 847-439-7320

www.intertek.com

The certificate and schedule are held in force by regular annual surveillance visits by Intertek Testing Services NA, Inc. and the reader or user should contact Intertek to validate its status. This certificate remains the property of Intertek Testing Services NA, Inc. and must be returned to them on demand. This Certificate is for the exclusive use of Intertek's Client and is provided pursuant to the Certification agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this certificate. Only the Client is authorized to permit copying or distribution of this certificate and then only in its entirety. Use of Intertek's Certification mark is restricted to the conditions laid out in the agreement. Any further use of the Intertek name for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. Initial Factory Assessments and Follow up Services are for the purpose of assuring appropriate usage of the Certification mark in accordance with the agreement, they are not for the purposes of production quality control and do not relieve the Client of their obligations in this respect.

LISTING INFORMATION

Product Covered
Halspan – Universal HD Core Wooden Door with Composite / Steel Frame Assembly – UL 10C.

Product Description
Halspan – Universal HD Core Wooden Door with wood composite / Steel Frames

Composite door frame is constructed with plywood and high density mineral (1200kg/m^3) layers with an overall jamb depth of 120mm, stop height 18mm.
Steel door frame (for use with 52mm thick doors) is constructed using 1.5mm thick galvanized steel sheet with a jamb depth of 150mm and must be cement grouted.

Door leaf is constructed with Halspan - Universal HD core with 3mm HDF facing for 45mm thick leaf / Universal HD core with 3mm HDF sub facing and 3mm thick MDF facing for 52mm thick leaf.
Additional 3mm MDF/HDF facings may be added on the faces of the door leaves.

Maximum sizes:

Details	Fire rating	Tested size	
Single Leaf Door Assembly	60 minutes	Frame	1272 x 2484 x 120mm (w x h x jamb depth)
		Leaf	1200 x 2440 x 45mm (w x h x thk)
Single Leaf Door Assembly*	90 minutes	Frame	1272 x 2484 x 120mm (w x h x jamb depth)
		Leaf	1200 x 2440 x 52mm (w x h x thk)
Double Leaf Door Assembly*	60 minutes	Frame	2479 x 2482 x 120mm (w x h x jamb depth)
		Leaf	1200 x 2440 x 52mm (w x h x thk)

*The doors may also be installed in cement grouted steel frame (Category C) with SLS-PLA-384 or SLS-PLA-386 intumescent strip centrally placed on leaf edge.

Limitations:
Minimum latch throw - 12mm, listed mortise lockset operated by lever handles or operated by panic bars provided the hardware-set is listed for use as fire exit hardware according to UL 10C. Surface mounted single point rim-type fire exit hardware may also be installed on the active leaf of double door or single leaf doors and surface mounted top and bottom rods fire exit hardware may be installed on inactive leaf of double door assemblies in lieu of the tested tower bolts, provided the hardware is listed as fire exit hardware according to UL 10C. Please note that the fire exit hardware must be listed according to UL 10C for fire protection rating with mineral core-based doors for at least the same fire rating duration as the Universal HD door it has to be installed with. Concealed vertical rod-based fire exit hardware is not allowed
Vision panel is allowed for up to 60-minutes fire rating in minimum 52mm thick single leaf or double leaf doors. Glass must be 5mm thick Pyran Platinum or alternative listed ceramic glazing - Maximum size (Glass): 250 x 500mm (w x h), installed using steel glazing beads with stop height of 21.5mm and with ceramic glazing tapes. Vision panel aperture must be covered with 2mm thick aperture liner (ref: Therm A Strip).
Grooves on the door surface are permitted, provided that a MDF facing of up to 3 mm thickness is added over the basic door construction. The depth of the grooves shall not penetrate or reach the basic door construction. In addition, the grooves shall not extend in between the door leaf and frame stop.
Supporting Construction - Masonry walls.

Fire Rating
The product noted above has been tested and qualified per UL 10C standard for Positive Pressure Fire Rating.

Also meets the requirements of UL 10B for Negative Pressure Fire Rating, NFPA 252 and CAN/ULC S104 for Positive Pressure Fire Rating.

Test Report Reference: YG022-3 (Rev.01), YG022-5 (Rev.01), YG022-6 (Rev.01) and ZF099-2.