Certificate of Compliance

You have been awarded:

Intertek WH US + C Mark for Category C - Proprietary Frames

Standards: CAN / ULC S104 (2015) (R2020), UL 10(b) (2008) (R2015), NFPA 252 (2017), UL 10(c) (2016) Ed. 3 (R:27 May 2021)

Certificate number: WHI26-28731468

This is a certificate of compliance to certify that the bearer has successfully completed the requirements of the above scheme which include the testing of products, the initial assessment, and are subject to continuing annual assessments of their compliance and testing of samples of products taken from production (as applicable to the scheme) and has been registered within the scheme for the products detailed.

Organization: ARFAD International Industry Company
Building No. 4177, Road 118, 3rd Industrial Area
Al Jubail 35729
Kingdom of Saudi Arabia

Product: Halspan – Halspan Universal HD 51mm Mineral Frame – UL 10C
Spec ID: 85472
Fire Rating: 60 Min PP Category C Proprietary Frame, 90 Min PP Category C Proprietary Frame
Listing Information: See following page(s)

Certification body: Intertek Testing Services NA, Inc.
Initial registration: February 21, 2026
Date of expiry: December 31, 2026
Issue status: 1

Authorized By:
Jean-Philippe Kayl, Director of Certification

Intertek Testing Services NA, Inc.
545 E. Algonquin Road, Ste H., Arlington Heights, IL 60005 USA
Phone: 847-439-5667 Fax: 847-439-7320

www.intertek.com

The certificate and schedule are held in force by regular annual surveillance visits by Intertek Testing Services NA, Inc. and the reader or user should contact Intertek to validate its status. This certificate remains the property of Intertek Testing Services NA, Inc. and must be returned to them on demand. This Certificate is for the exclusive use of Intertek's Client and is provided pursuant to the Certification agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this certificate. Only the Client is authorized to permit copying or distribution of this certificate and then only in its entirety. Use of Intertek's Certification mark is restricted to the conditions laid out in the agreement. Any further use of the Intertek name for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. Initial Factory Assessments and Follow up Services are for the purpose of assuring appropriate usage of the Certification mark in accordance with the agreement, they are not for the purposes of production quality control and do not relieve the Client of their obligations in this respect.

LISTING INFORMATION

Product Covered
Halspan – Halspan Universal HD 51mm Mineral Frame – UL 10C.
Category C - Proprietary Frame

Product Description
Halspan – Halspan Universal HD 51mm Mineral Frame – UL 10C.

Door frame is constructed in single rebbeted design with sandwiched plywood and high density mineral (1200kg/m^3) layers with an overall jamb depth of 120mm, stop height 18mm, rebate 55mm, face width 51mm. Intumescent seal - 25 x 6mm (w x thk), Halspan ref: SLS-PAL-130 self-adhered into the grooves on the rebate of both vertical edges and on the head of the door frame

For use with Category A or Category B doors - 25 x 6mm (w x thk), Halspan ref: SLS-PAL-130 intumescent seal or equivalent Category G intumescent seal, self-adhered into the grooves on the rebate of both vertical edges and on the head of the door frame.

Supporting Construction - Masonry wall

Maximum sizes:

Details	Fire rating	Tested size
Single Leaf Door Frame	90 minutes	1272 x 2484 x 120mm (w x h x jamb depth)
Double Leaf Door Frame	60 minutes	2479 x 2482 x 120mm (w x h x jamb depth)

Fire Rating
The product noted above has been tested and qualified per UL 10C standard for Positive Pressure Fire Rating.

Also meets the requirements of UL 10B & CAN/ULC S104 (Neutral Pressure Fire Rating) and NFPA 252 (Positive Pressure Fire Rating) .

Test Report Reference: YG022-5 (Rev.01) and YG022-6 (Rev.01).