Certificate of Compliance

You have been awarded:

WH Service Mark 2014 for Category D - Door/frame Assemblies

Standards: BS 476 Part 22 (1987), BS 476 Part 20 (1987)

Certificate number: WHI22-28731445

This is a certificate of compliance to certify that the bearer has successfully completed the requirements of the above scheme which include the testing of products, the initial assessment, and are subject to continuing annual assessments of their compliance and testing of samples of products taken from production (as applicable to the scheme) and has been registered within the scheme for the products detailed.

Organization: ARFAD International Industry Company
Building No. 4177, Road 118, 3rd Industrial Area
Al Jubail 35729
Kingdom of Saudi Arabia

Product: RAMKOR - FD120 Plus - 120 Minute Fire-Rated Particle Board Core Door
Spec ID: 44704
Fire Rating: 2 Hour Fire Rated
Listing Information: See following page(s)

Certification body: Intertek Testing Services NA, Inc.
Initial registration: October 22, 2022
Date of expiry: December 31, 2026
Issue status: 5

Authorized By: _____
Jean-Philippe Kayl, Director of Certification

Intertek Testing Services NA, Inc.
545 E. Algonquin Road, Ste H., Arlington Heights, IL 60005 USA
Phone: 847-439-5667 Fax: 847-439-7320

www.intertek.com

The certificate and schedule are held in force by regular annual surveillance visits by Intertek Testing Services NA, Inc. and the reader or user should contact Intertek to validate its status. This certificate remains the property of Intertek Testing Services NA, Inc. and must be returned to them on demand. This Certificate is for the exclusive use of Intertek's Client and is provided pursuant to the Certification agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this certificate. Only the Client is authorized to permit copying or distribution of this certificate and then only in its entirety. Use of Intertek's Certification mark is restricted to the conditions laid out in the agreement. Any further use of the Intertek name for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. Initial Factory Assessments and Follow up Services are for the purpose of assuring appropriate usage of the Certification mark in accordance with the agreement, they are not for the purposes of production quality control and do not relieve the Client of their obligations in this respect.

LISTING INFORMATION

Product Covered

RAMKOR FD120 Plus - 120 Minute Fire-Rated Particle Board Core Door

Product Description

Single leaf single acting doorset in wood frame:

Door Leaf core - Ramkor FD120 Plus - 78mm thick
Door frame - Hardwood (density - 750 kg/m^3 (minimum))

Door leaf size - 930mm x 2176mm x 79mm (w x h x thk.)
Door frame size - 1020mm x 2230mm x 140mm (w x h x jamb depth)

The door leaf has a 19mm x 19mm rebate cut off on the push side of the door on both vertical edges and the top horizontal edge.
3mm thick wood lipping is used on the vertical edges and 5mm thick wood lipping is used along the rebate. (lipping density - 750 kg/m^3 (minimum))
The doors have wood veneer facings (0.5mm thick) on both sides.

Minimum Latch Throw - 12mm

Supporting Construction - Masonry wall.

Fire Ratings

The latched flush single leaf single acting doorset in wood frame have been qualified for following ratings according to BS 476 Part 22 (1987):

Integrity - 125 Minutes
Insulation - 125 Minutes

Note - Vision panel not allowed.