Certificate of Compliance

This is a certificate of compliance to certify that the bearer has successfully completed the requirements of the above scheme which include the testing of products, the initial assessment, and are subject to continuing annual assessments of their compliance and testing of samples of products taken from production (as applicable to the scheme) and has been registered within the scheme for the products detailed.

You have been awarded:

Intertek WH US + C Mark for Category A - Doors - No Additional Edge-sealing System Required

Standards: UL 10(c) (2009), CAN / ULC S104 (2010), NFPA 252 (2012), CAN / ULC S104 (2015) (R2020), UL 10(c) (2016), NFPA 252 (2017)

Certificate number: WHI18-28731415

Organization: ARFAD International Industry Company
Building No. 4177, Road 118, 3rd Industrial Area
Al Jubail 35729
Kingdom of Saudi Arabia

Product: Warm Springs 45-90 Minute Flush Doors
Spec ID: 30393
Fire Rating: 45 Min Neutral Pressure, 60 Min PP Category A Door, 90 Min Neutral Pressure, 90 Min PP Category A Door, 45 Min PP Category A Door, 60 Min Neutral Pressure
Listing Information: See following page(s)

Certification body: Intertek Testing Services NA, Inc.
Initial registration: March 13, 2018
Date of expiry: December 31, 2026
Issue status: 10

Authorized By: _____
Jean-Philippe Kayl, Director of Certification

Intertek Testing Services NA, Inc.
545 E. Algonquin Road, Ste H., Arlington Heights, IL 60005 USA
Phone: 847-439-5667 Fax: 847-439-7320

www.intertek.com

The certificate and schedule are held in force by regular annual surveillance visits by Intertek Testing Services NA, Inc. and the reader or user should contact Intertek to validate its status. This certificate remains the property of Intertek Testing Services NA, Inc. and must be returned to them on demand. This Certificate is for the exclusive use of Intertek's Client and is provided pursuant to the Certification agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this certificate. Only the Client is authorized to permit copying or distribution of this certificate and then only in its entirety. Use of Intertek's Certification mark is restricted to the conditions laid out in the agreement. Any further use of the Intertek name for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. Initial Factory Assessments and Follow up Services are for the purpose of assuring appropriate usage of the Certification mark in accordance with the agreement, they are not for the purposes of production quality control and do not relieve the Client of their obligations in this respect.

LISTING INFORMATION

Composite Core Type, Swinging Flush Design Fire Door for installation in single swing or standard pairs 45 to 90 Minute locations.

LIMITATIONS

The following limitations are subject to specific door construction requirements. Please refer to Manufacturing and Machining sections of this Listing.

Minimum overall door thickness: 1-11/16"
Mortised or cylindrical latches with up to a 5" backset
Mortised automatic flushbolts
Mortised or surface mounted rim type fire exit hardware
Surface mounted vertical rod fire exit hardware
Concealed Vertical Rod (CVR) hardware
Electrical wire raceways
Vision panels: max. 100 sq.in. (90 min.)
Vision panels: max. 616 sq.in. each lite, max 1232 sq.in (45 & 60 min.)
Louvers: max. 524 sq.in.
Temperature Rise - 250°F @ 30 minutes
Surface mounted closers
Wood surface veneer
Plastic laminate veneer 0.050" thick
Wood crossbanding 1/16" thick
Surface mounted or mortised door bottoms
Concealed closer track and arm (45-60 min. only)

Maximum Size of Openings

The maximum opening sizes are subject to specific door construction requirements. Please refer to the Manufacturing section of this Listing.

CORE TYPE	SWING	MAXIMUM SIZE
Thermal-Lite	Single	4'0" wide x 8'0" high 3'0" wide x 8'0" high*
	Pairs	6'0" wide x 7'0" high**
		7'0" wide x 8'0" high***
MDS Mineral Core	Single	4'0" wide x 9'0" high
	Pairs	8'0" wide x 9'0" high****
AHI	Single	4'0" wide x 9'0" high
	Pairs	8'0" wide x 9'0" high****
G-P Gypsum	Single	4'0" wide x 8'0" high
	Pairs	8'0" wide x 8'0" high
WSCP-412	Single	4'0" wide x 9'0" high
	Pairs	8'0" wide x 8'0" high*

*Additional requirements as noted in Manufacturing section
**3-point latching and 5" Tectonite meeting stile required

***4-point latching and 2" Tectonite stiles required
****4-point latching and 5" Tectonite stiles required for pairs over 8 ft. in height.

Evaluated to the following...

Positive Pressure - Category A
This category includes doors evaluated without an edge-sealing system between the door and frame. It also includes doors evaluated with a sealing system incorporated (concealed or visible) into the edge of the door by the licensed manufacturer or machining distributor.
Meeting edges of pairs may require an astragal or an edge-sealing system. Please refer to individual door listings.
These doors are eligible for use in any "Category C - Standard" frame. These doors may also be installed in frames listed in "Category C - Proprietary" in the accordance with the frame manufacturer's individual listing.
All doors listed in Category A are eligible to bear the "S" (for Smoke & Draft Control assemblies) if a listed "Category H - Smoke & Draft Control Gasket" has been applied to the assembly. Please refer to Category H for individual gasket manufacturer's listings.
All doors in this category are identified by a label or marking bearing the wording, "Listed Fire Door", a time interval, a temperature rise rating, a serial number and the Warnock Hersey Certification Mark and "UL 10C".